

Minuteman - ETR2000LGU : ETR2000LGU

| ecifications | |
|--|----------------------------|
| | |
| RGY STAR Unique ID: 24065 | 544 |
| d Name: Minut | eman |
| el Name: ETR20 | 000LGU |
| el Number: ETR20 | 000LGU |
| er Conversion Mechanism: Static | |
| mum Configuration Tested Model ETR20 ber: | 000LGU |
| ve Output Power Rating Minimum 1200 figuration (W): | |
| arent Output Power Rating Minimum 1920 figuration (VA): | |
| blogy (ac): Line I | nteractive |
| ology and Product Type Combined: ac Lin | ne Interactive (VI) |
| ication: Data | Center,Consumer,Commercial |
| d Input Voltage (V rms): 120-1 | 20 |
| d Input Frequency (Hz): 60-60 | |
| d Output Voltage (V): 120-1 | 20 |
| d Output Frequency (Hz): 60-60 | |
| Mountable: No | |
| ht (mm): 280 | |
| h (mm): 99 | |
| t h (mm): 410 | |
| I Number of Outlets: 8 | |
| ber of Battery Backup and Surge 4 ected Outlets: | |
| ber of Surge Protected Only Outlets: 4 | |
| nal Mode(s) Input Dependency Voltage vacteristic (ac): | ge Independent |
| ular UPS: No | |
| ber of Normal Modes: Single | e-normal-mode |
| ult Normal Mode (ac): Voltag | ge Independent |
| Input Voltage (V rms): 120 | |
| Input Frequency (Hz): 60 | |
| Output Voltage (V): 120 | |
| Output Frequency (Hz): 60 | |

| Efficiency at 25% Load Min Config Lowest Dependency (ac): | 98.2 |
|--|---|
| Efficiency at 50% Load Min Config Lowest Dependency (ac): | 98.6 |
| Efficiency at 75% Load Min Config Lowest Dependency (ac): | 98.4 |
| Efficiency at 100% Load Min Config Lowest Dependency (ac): | 98.4 |
| Weighted Efficiency Calc Min Config Lowest Dependency: | 98.4 |
| Efficiency (%): | 98.4 |
| Modular UPS Module Tested Model Number: | N/A |
| Energy Storage Mechanism: | Battery |
| Energy Storage System Technology: | Valve Regulated Lead-acid Battery |
| Energy Storage System Configuration: | Integral |
| Energy Storage System Removable to Another Room: | N/A |
| Energy Storage System Runtime at 100% Load (min.): | 2 |
| Energy Storage System Runtime at 50% Load (min.): | 10 |
| Energy Storage System Warranty (yrs): | 2 |
| Energy Storage System Information URL: | https://minutemanups.com/uninterruptible-power-supply/ |
| Battery Recycling URL: | https://minutemanups.com/contact/ |
| Network Connections Available: | USB Port |
| Communication Protocols: | Other |
| Communication Protocol Other: | HID |
| Manufacturer Take Back Program: | Yes |
| Manufacturer Take Back Program URL: | https://minutemanups.com/contact/ |
| - | https://minutemanups.com/uninterruptible-power-supply/entrust-lg- uninterruptible-power-supply |
| Test Method Guidelines: | N/A |
| Date Available on Market: | 2023-04-01 |
| Date Certified: | 2023-01-05 |
| Markets: | United States, Canada |
| ENERGY STAR Certified: | Yes |

Captured On: 04/28/2025